

Declaration of performance



No.. 12013025

Product type Cable sealing system LS90

Type number 9459-01

Intended use Cable sealing for appropriate fire protection sealing of feed-throughs in fire protection walls

Manufacturer Kaiser GmbH & Co. KG
Ramsloh 4
58579 Schalksmühle

System for assessing and inspecting the constancy of performance 1

Notified body with details of their activities in respect of the product type listed above in accordance with European technical assessment:

The notified body of the "Materialprüfanstalt für das Bauwesen Braunschweig" (Materials Testing Institute for Construction Materials Brunswick) has carried out the initial inspection of the factory and the company's own production control in addition to the on-going monitoring, assessment and evaluation of the in-house production control in accordance with System 1, and has issued a certificate of conformity in accordance with the requirements of ETA-17/0449: **0761-CPR-0205**

Notified body with details of their activities in respect of the product type listed above in accordance with the harmonised standard:

Not relevant

Declared performance Class of reaction to fire **E** according to EN 13501-1

Declaration The product described complies with the performance characteristics. For the preparation of the declaration of performance in accordance with Regulation (EU) No. 305/2011 is solely the above mentioned manufacturers responsible.

Miscellaneous: The product described also complies with the requirements of **Low Voltage Directive 2014/35/EU**.

Name and function Dirk Umbach, Director Market and Innovation
Development

Schalksmühle, 28.01.2021

Place and date of issuance

Signature

A handwritten signature in blue ink is written over a horizontal line. To the right of the signature is the KAISER logo, which includes the stylized circular emblem and the text "KAISER GmbH & Co. KG Ramsloh 4 • D-58579 Schalksmühle".